


# ANNUAL REPORT 2012

Vermilion Bay  
Drinking Water System



Introduction	1
System Description	2
Water Quality	3
Flows	5
Compliance	7
Appendix A: Water Quality	9
Appendix B: Flow Statistics	11
Appendix C: AWQIs	12



Prepared by Northern Waterworks Inc.  
P.O. Box 1160, 104 Howey St.  
Red Lake, Ontario, P0V 2M0

## INTRODUCTION

The Vermilion Bay Drinking Water System (DWS# 210000997) is obligated to meet the requirements of Ontario's *Safe Drinking Water Act* and the regulations therein, in addition to requirements associated with system approvals. Specifically, this system must meet extensive treatment and testing requirements in order to ensure that human health is protected.

This Annual Report has been prepared in accordance with both Schedule 22 and section 11 of Ontario Regulation 170/03. In this manner, the Summary Reports for Municipalities required by Schedule 22 and the Annual Reports required by section 11 have been consolidated into a single document. This Report is intended to brief the ownership of the Vermilion Bay Drinking Water System (VBDWS) on the system's performance over the past calendar year (January 1, 2012 to December 31, 2012).

A summary of this Drinking Water System (DWS) is difficult to produce without the use of technical terms, some of which the reader may not be familiar with. It is recommended that the reader refer to the *Technical Support Document for Ontario Drinking Water Standards, Objectives, and Guidelines*. Within this document the reader will find information on provincial water quality standards, objectives and guidelines, rationale for monitoring, and a brief description of water quality parameters. This document can be found at the following website address:

[http://www.ene.gov.on.ca/stdprodconsume/groups/lr/ene/@resources/documents/resource/std01\\_079707.pdf](http://www.ene.gov.on.ca/stdprodconsume/groups/lr/ene/@resources/documents/resource/std01_079707.pdf)

Users of this Drinking Water System are also encouraged to contact a representative of Northern Waterworks Inc. for assistance in interpreting this Annual Report.

### Report Availability

In accordance with section 11 of O. Reg. 170/03, this Annual Report must be made available for inspection by any member of the public, without charge, at the Municipal Office. Additionally, the Municipality of Machin is encouraged to make available this Annual Report on the community's website.

In accordance with Schedule 22 of O. Reg. 170/03, this Annual Report must be distributed to the members of the municipal council. Effective January 1, 2013, section 19 (Standard of care, municipal drinking water system) of Ontario's *Safe Drinking Water Act* places certain responsibilities upon those municipal officials who oversee an accredited operating authority or exercise decision-making authority over a system. Such municipal officials would be exercising diligence by becoming familiar with this Annual Report.

## SYSTEM DESCRIPTION

Classified as a large municipal residential system, this drinking water system (DWS) provides a potable water supply to the community of Vermilion Bay. This DWS is composed of the Vermilion Bay Low Lift Pumping Station (VBLLPS), the Vermilion Bay Water Treatment Plant (VBWTP), and the Vermilion Bay distribution system. This DWS is owned by the Corporation of the Municipality of Machin and is operated by Northern Waterworks Inc. Potential pathogenic organisms are removed from the source water by coagulation, flocculation, sedimentation, filtration, and primary disinfection processes.

The VBLLPS draws surface water from Eagle Lake, such that two low lift pumps are capable of transferring the raw water from the source to the treatment units located at the VBWTP. Lime solution (pH/alkalinity adjustment) and polyaluminum chloride (primary coagulant) are injected into the raw water upstream from the treatment units. A cationic polymer (flocculation aid) is then injected during the flocculation stage in order to create a strong and dense floc, which will facilitate settling in the sedimentation stage. In the sedimentation tanks, water flows upward through a maintained floc blanket and tube settlers and enters the perforated clarifier effluent pipe which directs flow to the filters. Any suspended particles that did not settle in the sedimentation tanks will be removed by two dual-media filters (composed of anthracite and silica sand, on a layer of support gravel). Filter effluent is then directed to a non-chlorinated reservoir for subsequent transfer through the GAC (granular activated carbon) filter units. Sodium hypochlorite (disinfectant) is then added to the GAC filter effluent water.

The chlorinated water is held in the treated water storage reservoirs to allow for the necessary time required to achieve primary disinfection. Treated water is then transferred to the distribution system by the use of high lift pumps located at the VBWTP. Secondary disinfection requirements in the distribution system are achieved by the maintenance of a residual as free chlorine.

### System Expenses

It is within the scope of this Report to describe any major expenses incurred during the reporting period to install, repair or replace required equipment. Such major expenses for the Vermilion Bay DWS include:

- \$ 61,730.97 related to the damage caused by lightning and severe weather in June, including the replacement and repair of several pumps, an electric valve actuator, a flash mixer, and a transformer.

## WATER QUALITY

The Vermilion Bay Drinking Water System continued to produce water of exceptional quality in 2012. The descriptions below provide brief summaries of the parameters tested in the VBDWS, and the reader is asked to consult **Appendix A** for a comprehensive summary of 2012 water quality.

### In-House Analyses

The Vermilion Bay DWS employs an extensive in-house testing program which includes analyses of water quality indicators beyond that required by Ontario's *Safe Drinking Water Act*. Such analyses are conducted on source, treated, and process water, and include testing for turbidity, colour, pH, temperature, alkalinity, aluminum, and residual free chlorine. Approximately 5600 routine independent in-house water quality tests were conducted with respect to this system in 2012.

### Microbiological Analyses

Microbiological analyses are conducted on source, treated, and distribution system water. A total of 259 routine water samples were collected for bacteriological analysis by an accredited laboratory in 2012, as required by Schedule 10 of O. Reg. 170/03. These water samples were collected on a weekly basis, and included tests for *E. coli*, total coliforms, and heterotrophic plate counts. All routine samples tested absent for *E. coli* and total coliform parameters.

### Organic Parameters and Trihalomethanes

Organic parameters are sampled on an annual basis in treated water in accordance with Schedules 13 and 24 of O. Reg. 170/03. These parameters include various acids, pesticides, herbicides, PCBs, volatile organics, and other organic chemicals. With respect to the Vermilion Bay DWS, sampling for organic parameters was conducted on February 7, 2012. The results of all organic parameter testing were below the lower detectable limits (with the exception of trihalomethanes).

Trihalomethanes (THMs) are sampled on a quarterly basis from the farthest point in the Vermilion Bay distribution system, in accordance with Schedule 13 of O. Reg. 170/03. Compliance with the provincial standard for trihalomethane concentrations is determined by calculating a running annual average (with a Maximum Acceptable Concentration of 0.100 mg/L or 100 ug/L). In 2012, the running annual average was 74.9 ug/L.

## WATER QUALITY (continued)

### Inorganic Parameters and Nitrate/Nitrite

Inorganic parameters are sampled on an annual basis in treated water in accordance with Schedules 13 and 23 of O. Reg. 170/03. Inorganic sampling includes various parameters such as Antimony, Arsenic, Cadmium, Mercury, and Uranium. With respect to the Vermilion Bay DWS, required annual sampling for inorganic parameters was conducted on February 7, 2012.

Treated water is also tested for nitrate and nitrite concentrations on a quarterly basis in accordance with Schedule 13 of O. Reg. 170/03. There was no exceedance for any inorganic parameter in 2012.

### Community Lead Sampling

Based on results of the community lead sampling program, the Vermilion Bay DWS has qualified for reduced sampling in accordance with Schedule 15.1 of O. Reg. 170/03. Such reduced sampling will resume in the period corresponding to December 15, 2014 to April 15, 2015. A summary of lead sampling results from the reporting period is provided below.

#### 2012 Lead Sampling Results

Sample Type	Number of Samples	Minimum Result (ug/L)	Maximum Result (ug/L)	ODWQS <sup>1</sup> (ug/L)	Number of Exceedances	Number of Samples Below LDL <sup>2</sup> (<1.0 ug/L)	Number of Samples Between LDL and ODWQS
Plumbing	88	<1.0	12.6	10	1	48	39
Distribution	8	<1.0	3.2	10	0	2	6


1. ODWQS = Ontario Drinking Water Quality Standard; a value above this threshold is considered to be an exceedance.
2. LDL = lower detectable limit; lead concentrations below the LDL are not detected by current analytical methods.

# FLOWS

## 2012 Flows


Throughout the reporting period, the Vermilion Bay DWS supplied 58,217 m<sup>3</sup> of treated water to consumers. On an average day in 2012, 159.1 m<sup>3</sup> of treated water was supplied to the community. This average daily flow rate in 2012 represented 11.7 % of the rated capacity of the Vermilion Bay WTP (1,360 m<sup>3</sup>/day). The maximum daily flow rate in 2012 was 367 m<sup>3</sup>/day, which represented 27.0 % of the rated capacity of the Vermilion Bay WTP. The reader is asked to consult **Appendix B** for a complete summary of 2012 flow data.

### Daily Flows for the Vermilion Bay DWS



There was a decrease in the amount of water supplied in 2012 when compared to the previous calendar year. In 2011, 63,729 m<sup>3</sup> of treated water was supplied to users of the Vermilion Bay DWS, compared to 58,217 m<sup>3</sup> in 2012. This represents an 8.6% reduction in the amount of treated water supplied to the community. The reader is asked to consult **Appendix B** for a summary of historical flow data.

### Annual Flows for the Vermilion Bay DWS



## FLOWS (continued)

### Chemical Consumptions

Increases in the consumption of lime in recent years are associated with corrosion control measures intended to reduce lead concentrations in premise plumbing. These measures have proven effective in controlling lead release, and it is reasonable to expect that future lime dosages will be similar to those encountered in 2011 and 2012.

The table below summarizes all the water treatment chemicals used during the reporting period and their consumption data. All chemicals used in the treatment process are NSF 60 certified for use in potable water, as required by system approvals.

#### Chemical Consumptions & Average Dosages

Year	Lime		Polyaluminum chloride		Polymer		Sodium hypochlorite	
	Quantity Used (kg)	Average Dosage (mg/L)	Quantity Used (L)	Average Dosage (mg/L)	Quantity Used (kg)	Average Dosage (mg/L)	Quantity Used (L)	Average Dosage <sup>1</sup> (mg/L)
2010	287	3.5	4394	21.7	13.4	0.16	2262	3.86
2011	462	6.0	4306	22.5	7.6	0.10	2256	4.25
2012	417	5.8	3418	18.9	7.0	0.10	2469	5.09

1. GAC transfer volumes (as opposed to raw water volumes) are used in the average dosage calculations for sodium hypochlorite. Using such volumes provides a better indication of applied dosages. Discrepancies in the reported dosages between this and previous Annual Reports can be attributed to using raw water volumes in such calculations.

## COMPLIANCE

### Ensuring Compliance

Northern Waterworks Inc. operates the Vermilion Bay Drinking Water System for the Municipality of Machin, and must comply with legislative and regulatory requirements in addition to the terms and conditions of a number of site-specific system approvals. Staffing is maintained at levels to ensure that adequate numbers of trained and licensed personnel are available for proper operations, during emergency or upset conditions, for vacation/sick relief, or to deal with equipment breakdown. Emergency response procedures and operations manuals are established and located in the appropriate facilities, and are available to all staff members. Operations manuals include information necessary for the day-to-day operation and maintenance of the treatment and distribution systems, as well as information that may be required to be accessed quickly for various purposes. Emergency response procedures include information that may be required for proper operation of the system during emergency or upset conditions, and contains items such as emergency plans and contact lists.

The operational strategy of Northern Waterworks Inc. includes ensuring that permits and approvals are in place, ensuring efficient maintenance and operations, and ensuring that the quality of water supplied to its customers meets or exceeds the minimum requirements as set out in the *Safe Drinking Water Act*. It is also our responsibility to ensure that permissible flow rates are not exceeded. Flow measuring devices for measuring the amount of water taken and the amount of water supplied are calibrated annually. Accuracy in these measurements ensures that treatment chemicals are precisely applied and that flows do not exceed the capacity at which the system is designed to be effective. These flows are recorded to provide current and historical information for decision making purposes, in addition to being used by the Ministry of the Environment to review treatment operations.

Water quality analyzers are in place to continuously monitor water quality after critical treatment processes. Each filter is equipped with a filter effluent turbidity analyzer which monitors the amount of suspended particles in the water leaving the filter. A chlorine residual analyzer continuously monitors the free chlorine residual at a point where primary disinfection is complete. Each piece of equipment is equipped with an alarm indicating adverse water quality, and is maintained in accordance with manufacturer's recommendations. Additionally, a water sampling program is conducted to exceed the minimum requirements of O. Reg. 170/03 under the *Safe Drinking Water Act*. Raw water sampling is conducted to give operational staff the information required to effectively operate the treatment process, and samples are collected throughout the process to determine the effectiveness of treatment at each stage. Treated and distribution system sampling provide information regarding the quality of water delivered to consumers. All of these samples are analyzed by licensed staff or by an accredited laboratory.

### Compliance with System Approvals

The Municipal Drinking Water Licence for the Vermilion Bay DWS requires that effluent discharged into the natural environment has an annual average total suspended solids concentration below 15 mg/L. This effluent is returned to Eagle Lake, and originates from the water consumed for plant process purposes (such as filter backwashing, clarifier "desludging", and filter rinsing-to-waste). In 2012, the annual average concentration for decant effluent total suspended solids was 3.3 mg/L. The annual average concentration calculation assumes that sample results found to be below the lower detectable limit are equivalent to that limit.



## COMPLIANCE (continued)

### Incidents of Non-Compliance

There was one known incident of non-compliance in 2012. Such an incident contravenes regulatory requirements, and corrective actions are required to address such items.

#### Summary of 2012 Incident of Non-Compliance

Incident Description	Raw water samples were not collected and tested for the microbiological parameters of E. coli and total coliforms at the required minimum frequency. In accordance with Schedule 10 (Microbiological Sampling and Testing), subsection 10-4. (Raw water samples) of O. Reg. 170/03, raw water samples must be collected once per week and tested for the above parameters. A week is defined as the period of seven days that begins on Sunday and ends on the following Saturday.
Explanation	A raw water sample was not collected during the week beginning June 10, 2012. This corresponded to a period of time where significant damage was sustained by the Vermilion Bay DWS due to severe weather. The Vermilion Bay WTP was operational during at least part of the week, and as such raw water samples were required to be collected and tested for microbiological parameters.
Corrective Actions	No immediate corrective actions were taken to address this specific item of non-compliance, as it was only identified subsequent to the week in question. Routine microbiological sampling continued throughout 2012, which included collecting raw water samples every week. There have been no other instances of failing to collect samples at required minimum frequencies.

### Incidents of Adverse Water Quality

Under O. Reg 170/03, reporting procedures and corrective actions are required for any instance where a sample result shows that a parameter used to measure water quality exceeded a certain standard, or where other observations indicate that the safety of the water cannot be guaranteed. There were 5 such incidents for the Vermilion Bay DWS in 2012. Three of these incidents were directly attributable to the significant damage caused to the Vermilion Bay DWS by severe weather in June. The reader is asked to consult **Appendix C** for a summary of adverse water quality incidents which occurred in 2012.

## APPENDIX A: WATER QUALITY

### Microbiological Parameters

Parameter (Sample Type)	Units	Number of Samples	Minimum	Maximum	ODWQS <sup>1</sup>	Compliant ODWQS
E. Coli (Raw)	MPN/100mL	51	0	1	---	---
E. Coli (Treated)	p/a/100mL	52	absent	absent	not detectable	✓
E. Coli (Distribution)	p/a/100mL	156	absent	absent	not detectable	✓
Total Coliforms (Raw)	MPN/100mL	51	0	1200	---	---
Total Coliforms (Treated)	p/a/100mL	52	absent	absent	not detectable	✓
Total Coliforms (Distribution)	p/a/100mL	156	absent	absent	not detectable	✓
HPC (Treated)	CFU/mL	52	0	26	---	---
HPC (Distribution)	CFU/mL	105	0	6	---	---

1. ODWQS = Ontario Drinking Water Quality Standard; a value above this threshold is considered to be an exceedance.

### Chemical and Physical Parameters (In-House)

Parameter	Units	Number of Samples	Minimum <sup>1</sup>	Maximum	Annual Average <sup>3</sup>	Compliant ODWQS
Turbidity (Filter #1/#2)	NTU	Continuous	0.01/0.01	0.52/1.05 <sup>2</sup>	0.060/0.059	✓
Turbidity (Treated)	NTU	Continuous	0.072	0.263	0.110	---
Residual Free Chlorine	mg/L	Continuous	0.49	1.67	1.21	---
pH (Treated)	pH units	Continuous	6.5	7.5	7.1	---
Total Alkalinity (Treated)	mg/L CaCO <sub>3</sub>	~250	15.1	21.2	19.4	---
Residual Aluminum (Treated)	mg/L	~250	0.016	0.039	0.021	---

- The minimum and maximum values for the parameters of Turbidity (Treated), pH (Treated), Total Alkalinity (Treated), and Residual Aluminum (Treated) are given as minimum and maximum monthly averages.
- Maximum values for filter effluent turbidity are associated with adverse water quality incidents which had occurred in June 2012. Specifically, these maximum values for both filters were recorded on June 12, and were associated with catastrophic equipment failure which included damage to the SCADA system and plant PLCs. As such, these maximum values are corollaries of equipment failure, and are not indicative of actual high turbidity resulting from inadequate treatment processes. Please refer to the AWQIs detailed on Page 12.
- Annual averages are the averages of all in-house analyses conducted within the year for a given parameter.

### Inorganic Parameters

Parameter (Treated Water)	Units	Result	ODWQS	Compliant ODWQS
Antimony	ug/L	<0.60	6	✓
Arsenic	ug/L	<1.0	25	✓
Barium	ug/L	<10	1000	✓
Boron	ug/L	<50	5000	✓
Cadmium	ug/L	<0.10	5	✓
Chromium	ug/L	<1.0	50	✓
Fluoride	mg/L	<0.030	1.5	✓
Mercury	ug/L	<0.10	1	✓
Selenium	ug/L	<1.0	10	✓
Sodium	mg/L	6.95 <sup>1</sup>	20 <sup>2</sup>	✓
Uranium	ug/L	<2.0	20	✓

- Treated water must be tested for sodium concentrations once every 5 years. This most recent result pertains to a sample collected on February 22, 2010.
- This value for the parameter Sodium is not associated with a Standard as prescribed in O. Reg. 169/03, although an exceedance of this value is associated with reporting requirements and corrective actions.

### Nitrate & Nitrite

Sample Date (2012)	Nitrate Result (mg/L)	Nitrite Result (mg/L)	Nitrate + Nitrite (mg/L)	Compliant ODWQS
February 7	0.039	<0.020	0.039	✓
May 14	0.038	<0.020	0.038	✓
August 7	0.046	<0.020	0.046	✓
November 13	0.033	<0.020	0.033	✓
ODWQS (mg/L)	10	1	10	

## APPENDIX A: WATER QUALITY (continued)

### Organic Parameters

Parameter (Treated Water)	Result (ug/L)	ODWQS (ug/L)	Compliant ODWQS	Parameter (Treated Water)	Result (ug/L)	ODWQS (ug/L)	Compliant ODWQS
Alachlor	<0.10	5	✓	Diquat	<1.0	70	✓
Aldicarb	<1.0	9	✓	Diuron	<1.0	150	✓
Aldrin + Dieldrin	<0.040	0.7	✓	Glyphosate	<5.0	280	✓
Atrazine + N-dealkylated metabolites	<0.20	5	✓	Heptachlor + Heptachlor Epoxide	<0.20	3	✓
Azinphos-methyl	<0.10	20	✓	Lindane (Total)	<0.10	4	✓
Bendiocarb	<0.20	40	✓	Malathion	<0.10	190	✓
Benzene	<0.50	5	✓	Methoxychlor	<0.10	900	✓
Benzo(a)pyrene	<0.010	0.01	✓	Metolachlor	<0.10	50	✓
Bromoxynil	<0.20	5	✓	Metribuzin	<0.10	80	✓
Carbaryl	<0.20	90	✓	Monochlorobenzene	<0.50	80	✓
Carbofuran	<0.20	90	✓	Paraquat	<1.0	10	✓
Carbon Tetrachloride	<0.5	5	✓	Parathion	<0.10	50	✓
Chlordane (Total)	<0.3	7	✓	Pentachlorophenol	<0.50	60	✓
Chlorpyrifos	<0.10	90	✓	Phorate	<0.10	2	✓
Cyanazine	<0.10	10	✓	Picloram	<0.20	190	✓
Diazinon	<0.10	20	✓	Polychlorinated Biphenyls (PCBs)	<0.035	3	✓
Dicamba	<0.20	120	✓	Prometryne	<0.10	1	✓
1,2-Dichlorobenzene	<0.50	200	✓	Simazine	<0.10	10	✓
1,4-Dichlorobenzene	<0.50	5	✓	Temephos	<0.10	280	✓
DDT + metabolites	<0.40	30	✓	Terbufos	<0.20	1	✓
1,2-Dichloroethane	<0.50	5	✓	Tetrachloroethylene	<0.50	30	✓
1,1-Dichloroethylene	<0.50	14	✓	2,3,4,6-Tetrachlorophenol	<0.50	100	✓
Dichloromethane	<0.50	50	✓	Triallate	<0.10	230	✓
2,4 -Dichlorophenol	<0.30	900	✓	Trichloroethylene	<0.50	5	✓
2,4-Dichlorophenoxy acetic acid	<0.20	100	✓	2,4,6-Trichlorophenol	<0.50	5	✓
Diclofop-methyl	<0.20	9	✓	2,4,5-Trichlorophenoxy acetic acid	<0.20	280	✓
Dimethoate	<0.10	20	✓	Trifluralin	<0.10	45	✓
Dinoseb	<0.20	10	✓	Vinyl Chloride	<0.50	2	✓

### Trihalomethanes

Sample Date (2012)	Total THMs Result (ug/L)	2012 Annual Average (ug/L)	2011 Annual Average (ug/L)	2010 Annual Average (ug/L)	2009 Annual Average (ug/L)	ODWQS <sup>1</sup> (ug/L)	Compliant ODWQS
February 7	71.2						
May 14	54.3						
August 7	90.5						
November 13	83.4						
		74.9	79.9	52.6	47.0	100	✓

1. ODWQS = Ontario Drinking Water Quality Standard; a value above this threshold is considered to be an exceedance.

## APPENDIX B: FLOW STATISTICS

### 2012 Flow Statistics (values expressed as m<sup>3</sup>)

Month	Total Raw Water Flow	Total Treated Water Flow <sup>1</sup>	Average Treated Water Daily Flow <sup>1</sup>	Maximum Treated Water Daily Flow <sup>2</sup>	Plant Efficiency	Capacity Performance (Average Flows)	Capacity Performance (Maximum Flows)
Jan.	4,837	3,848	124	174	79.6%	9.1%	12.8%
Feb.	4,560	3,669	127	183	80.5%	9.3%	13.5%
March	4,818	3,860	125	223	80.1%	9.2%	16.4%
April	5,017	4,049	135	205	80.7%	9.9%	15.1%
May	6,678	5,492	177	269	82.2%	13.0%	19.8%
June	7,900	6,526	218	347	82.6%	16.0%	25.5%
July	9,731	8,088	261	367	83.1%	19.2%	27.0%
Aug.	7,641	6,165	199	308	80.7%	14.6%	22.6%
Sept.	6,375	5,154	172	250	80.8%	12.6%	18.4%
Oct.	5,510	4,349	140	231	78.9%	10.3%	17.0%
Nov.	4,560	3,509	117	171	77.0%	8.6%	12.6%
Dec.	4,791	3,508	113	190	73.2%	8.3%	14.0%
<b>Total</b>	<b>72,418</b>	<b>58,217</b>	---	---	---	---	---
<b>Avg.</b>	<b>6,035</b>	<b>4,851</b>	<b>158.9</b>	---	---	---	---

1. The recirculation of treated water via pressure relief valves located downstream of the treated water (distribution) flowmeter had previously resulted in inaccurate estimates with respect to the amount of water being supplied to the community. For this reason, the values for total treated water flow and average treated water daily flow were derived from actual transfer flows through the GAC filter units. In this way, such flows were not derived from data collected from the treated water (distribution) flowmeter.
2. Values for maximum daily flows were derived from data collected from the treated water (distribution) flowmeter.

### Flow Statistics by Year (values expressed as m<sup>3</sup>)

Year	Total Raw Water Flow	Total Treated Water Flow <sup>1</sup>	Plant Efficiency	% Change in Total Raw Flow from Previous Year	% Change in Total Treated Flow from Previous Year
2010	81,227	70,388	86.7%	---	---
2011	76,863	63,729	82.9%	-5.4%	-9.5%
2012	72,418	58,217	80.4%	-5.8%	-8.6%

1. Estimates for total treated water annual flow were derived from actual transfer flows through the GAC filter units. Previous Annual Reports derived such estimates from the treated water (distribution) flowmeter, and as such there is discrepancy with the estimates provided above. The estimates provided in this Report are considered to be more accurate in depicting the actual amount of treated water supplied to the community.

## APPENDIX C: ADVERSE WATER QUALITY INCIDENTS

### 2012 Adverse Water Quality Incidents

<b>AWQI#: 106362</b>	Incident Date: June 10, 2012	Resolution Date: June 12, 2012
Incident Description	Data from continuous monitoring equipment (distribution turbidimeter) was not being recorded. This incident represented the initial reporting of the widespread equipment failure caused by severe weather. The incident was reported to the NWHU and MOE SAC.	
Corrective Action(s)	Corrective action involved re-programming and calibrating the affected monitoring equipment. While trending was still absent, the equipment was made operational the same day.	
<b>AWQI#: 106363</b>	Incident Date: June 10, 2012	Resolution Date: June 12, 2012
Incident Description	The scope of critical equipment failure caused by the lightning damage resulted in observations that the safety of water could not be guaranteed. Among the many consequences of the widespread equipment failure was a temporary loss of standby power and low distribution system pressure. The incident was reported to the NWHU and MOE SAC.	
Corrective Action(s)	Significant emergency response actions were conducted immediately following the initial damage. NWI and sub-contracted personnel were involved in evaluating the extent of damage and arranging for the repair or replacement of equipment. The MOE and the NWHU remained informed of applied corrective actions.	
<b>AWQI#: 106364</b>	Incident Date: June 10, 2012	Resolution Date: June 12, 2012
Incident Description	The scope of critical equipment failure caused by the lightning damage resulted in observations that the safety of water could not be guaranteed. Among the many consequences of the widespread equipment failure was the loss of recorded data from continuous monitoring equipment. The incident was reported to the NWHU and MOE SAC.	
Corrective Action(s)	Immediate corrective action prescribed by the NWHU involved monitoring and recording distribution turbidity and residual free chlorine every five minutes. CPUs, various PLC modules, and power supplies were subsequently replaced. The SCADA system was re-programmed and integrated as the monitoring equipment was re-commissioned. Such actions were part of larger emergency response actions aimed at re-commissioning the WTP. There were various corollaries of the critical equipment failure and resulting corrective actions, such as erroneously high filter effluent turbidity measurements. The MOE and the NWHU remained informed of applied corrective actions.	
<b>AWQI#: 106604</b>	Incident Date: June 22, 2012	Resolution Date: June 22, 2012
Incident Description	Data from continuous monitoring equipment was not recorded due to significant software issues with the SCADA system. The incident was reported to the NWHU and MOE SAC.	
Corrective Action(s)	The SCADA computer was replaced and re-commissioned the same day. Trending (i.e. the recording of continuously monitored data) was confirmed to be operational.	
<b>AWQI#: 106670</b>	Incident Date: June 25, 2012	Resolution Date: June 27, 2012
Incident Description	Data from continuous monitoring equipment was not being recorded (i.e. a loss of SCADA trending). The reason for the loss of trending was not immediately determined. The incident was reported to the NWHU and MOE SAC.	
Corrective Action(s)	Immediate corrective action prescribed by the NWHU involved verifying alarm systems daily, confirming analyzer accuracy, and ensuring an operator is on-site when producing treated water. Additionally, filter effluent turbidity was manually recorded every 15 minutes while the plant was in operation. The cause of the loss of trending was subsequently determined to be an inappropriate set point on the SCADA computer which resulted in the computer shutting off. The set point was changed and trending was restored.	

1. MOE SAC – Ministry of the Environment Spills Action Centre